



FA # \_\_\_\_\_

PR # \_\_\_\_\_

An inspection of the swimming pool/spa was conducted and the inspector was unable to verify that the GFCI was working correctly. Please verify and submit this form within 14 days to avoid a re-inspection fee as well as be subject to closure of the pool/spa.

Swimming Pool Electrical Inspection Report for GFCI

California Code of Regulation Article 79, section 25.69.20 Underwater Lighting Fixtures states

(a) A ground-fault circuit interrupter shall be installed in the branch circuit supplying underwater fixtures operating at more than 15 volts.

Name of Pool: \_\_\_\_\_

Address of Pool: \_\_\_\_\_

City, Zip Code: \_\_\_\_\_ Phone # \_\_\_\_\_

Manager/Contact: \_\_\_\_\_

Manager Mailing Address: \_\_\_\_\_ City,

Zip Code: \_\_\_\_\_ Phone# \_\_\_\_\_

Email: \_\_\_\_\_

The undersigned certifies, under the penalty of perjury, to the safe installation of the GFCI which is in compliance with all applicable state laws and local ordinances.

Inspection completed by: \_\_\_\_\_

Type of Certification and number: \_\_\_\_\_

*Grounded in Health*